

GENERATOR PERMIT CONDITIONS

THIS FORM MUST BE SUBMITTED ALONG WITH A COMPLETED PERMIT APPLICATION

It is recommended to set up an onsite meeting with inspectors prior to submitting for permit

Two(2) copies of the following documents shall be submitted for review:

- Plat of Survey indicating proposed site
- Set of equipment cut sheets
- Line diagrams indicating all wiring
- Gas line diagrams and sizing
- Drawings depicting location of generator, transfer switch and panel

New installations of generators are NOT permitted in any required side yard.

Generator: New Replacement

Distance from side lot line: _____ (R-1 minimum 7' and R-2 minimum 6')

Distance from rear lot line: _____ (minimum 20')

Distance from building openings such as windows, doors and intakes: _____ minimum 5')

Distance from Gas meter or Regulator: _____ (minimum 5')

Distance from building: _____ (minimum 18" from masonry, 5' all other surfaces)

Type of Fuel: _____

Transfer switch: manual _____ automatic _____ (please check one)

Output capacity: _____KW

If you have any questions, please contact the Building Department:

John Montejo (847) 588-8067 Electrical Inspector jpm@vniles.com

Dan Macias (847) 588-8068 Mechanical Inspector dm@vniles.com

Required Inspections: Contractors to be on site for all inspections.

Pre-Pour Electrical Mechanical

